



NOTES:

1. PIPE ZONE MATERIAL SHALL BE 3/4"-0" CRUSHED ROCK GRANULAR BACKFILL COMPACTED TO 95% OF AASHTO T-99.
2. CLASS "A" NATIVE BACKFILL MAY ONLY BE USED OUTSIDE OF PAVED AREAS AND REQUIRES OLWS APPROVAL. BACKFILL SHALL BE COMPACTED TO 90% OF AASHTO T-99 IN LIFTS NOT EXCEEDING 18" (LOOSE MEASURE).
3. CLASS "B" 3/4"-0" CRUSHED ROCK GRANULAR BACKFILL SHALL BE USED WITHIN PAVED AREAS. BACKFILL SHALL BE COMPACTED TO 95% OF AASHTO T-99.
4. BACKFILL SHALL BE PLACED AND COMPACTED IN A MAXIMUM OF 24-INCH LIFTS. COMPACTION TESTING REQUIRED AT A FREQUENCY OF 1 TEST EVERY 100 FEET OF TRENCH.
5. RESURFACING TO BE MINIMUM 4 INCHES 1/2-INCH LEVEL 2 HMAC (PG 64-22) OR MATCH EXISTING, WHICHEVER IS GREATER.
6. SAWCUT WIDTH AND AC PAVEMENT REPLACEMENT SHALL BE PER APPLICABLE JURISDICTIONAL REQUIREMENTS. SAWCUT CLEAN EDGE FOR AC PAVEMENT REPLACEMENT. SAND SEAL JOINT.
7. PROVIDE CLASS "E" CDF BACKFILL FOR ALL TRENCH CROSSINGS LOCATED IN VEHICLE TRAVEL LANES OF ARTERIAL & COLLECTOR STREETS, OR WHERE CONCRETE PANELS ARE ENCOUNTERED. IF THESE SPECIFICATIONS CONFLICT WITH THE SPECIFICATIONS OF ANOTHER APPLICABLE JURISDICTION, THE MORE STRINGENT SPECIFICATION SHALL GOVERN.

OAK LODGE

WATER SERVICES

SANITARY SYSTEM STANDARD DRAWING

TYPICAL TRENCH DETAIL

DRAWING NO.

302

NO.	REVISIONS	DATE	BY
1			
2			
3			
4			

DATE: 09/12/2017

SCALE: NTS